

A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA190227

Date of Issue:

21 January 2019

Input: Max 580Vdc, MPP voltage range: 100-550Vdc, Max 12A/12A, Isc: 15/15A,

Class Description: Product Description:

Description

Max 3000W/3000W

Non-Declared Grid-tied Photovoltaic Inverter

Additional Models ESC3680-DS

ESC3000-DS

AC input & output: 230V~ 50/60Hz, Max 16A, 3680VA Battery: Lithium or lead-acid, 40-60Vdc, Max 50A 2500W Input: Max 580Vdc, MPP voltage range: 100-550Vdc, Max 12A/12A, Isc: 15/15A, Max 3000W/3000W AC input & output: 230V~ 50/60Hz, Max 13A, 3000VA

Battery: Lithium or lead-acid, 40-60Vdc, Max 50A 2500W

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





Issued: 21-01-19 190227/2